

Manual J Design Criteria^a

Elevation	Latitude	Winter Heating 99% Dry Bulb	Summer Cooling 1% Dry Bulb	Altitude Correction Factor	Indoor Design Temp.	Design Temp. Cooling	Heating Temp. Difference
5453' E. of Hwy. 93; Varies W. of Hwy. 93	40 ° North	1°	91°	.832 E. of Hwy. 93; Varies W. of Hwy. 93	70 °	75 °	69 °

Cooling Temperatur e Difference	Wind Velocity Heating	Wind Velocity Cooling	Coinciden t Wet Bulb	Daily Range	Winter Humidity	Summer Humidity	--
16 °	15 mph	7.5 mph	60	High (H)	30%	50%	--